



CERTIFICATE

CENTEXBEL TYPE TESTING | TEST REPORT N° 1904414

According to report N° A19.04414.01, dated on 3/09/2019 we confirm that the below mentioned item was tested at CENTEXBEL with reference to NEN-EN 15102:2007+A1:2011 – Decorative wall coverings – Roll and panel form.

The item shows

'EU fire classification B-s1,d0

'Compliance with migration of heavy metals and specific elements, maximum formaldehyde release and maximum vinyl chloride monomer (VCM) content'

Provided that it is properly applied.

The evaluation of these properties is based on evaluation scheme specified in NEN-EN 15102:2007+A1:2011 – Decorative wall coverings – Roll and panel form. These products come under the EU CPR 305/2011 directives for product safety.

SAMPLE

Non-woven wallpaper printed with Uvgel460 technology

Company

Océ-Technologies B.V.

PO box 101

NL- 5900 MA Venlo

The Netherlands

Certificate No. jw1805_2019 is valid until 22/08/2024

Centexbel | Technopark 7 | BE 9052 Gent | Belgium, 3/09/2019

Inge De Witte, PhD
Certification manager